# STATE OF WASHINGTON DEPARTMENT OF ECOLOGY

# GENERAL ORDER OF APPROVAL FOR DIESEL-POWERED EMERGENCY ELECTRICAL GENERATORS

General Order No. 05AQ-Gxxx Issued \_\_\_\_\_\_, 2006

Table 1: Applicability Criteria for this General Order of Approval

Criterion	Limitation
Fuel	Low-sulfur content: Not greater than 500 parts
	sulfur per million by weight (ppmw).
Generator set size	Not greater than 530 brake horsepower (BHP)
	engine
Diesel engine qualifications	Certified by manufacturer to meet the standards
	of 40 CFR Part 60 Subpart IIII (as proposed July,
	2005, see "Diesel engine qualifications" under
	item 2 of Approval Conditions).
	Documentation of manufacturer certification
	submitted with permit application.
Location	Located in counties or at industrial facilities
	under jurisdiction of the Department of Ecology
Minimum distances to property line and	If the exhaust stack extends at least ten feet above
publicly-accessible buildings vary with	the roof line, there are no location restrictions.
engine size	Engines under 100 BHP may use a shorter stack
	with location restrictions shown in <b>Table 2</b>
Allowed operating hours	Not more than 30 hours in any calendar year for
	required testing, and not more than 500 hours
	total operation in any calendar year.
Other criteria	1. The generator set is not part of a new major
	stationary source or major modification to a
	major stationary source which is subject to
	review under the Prevention of Significant
	Deterioration program.
	2. The addition of the generator set to an existing
	source does not make the source subject to the
	Air Operating Permit program or require a
	modification in an existing Air Operating
	Permit.

Table 2: Emergency Generator Placement, Small Engines with Stack Height Less Than 10 Feet Above Roofline

Engine BHP	Exhaust stack height above housing or adjacent building roofline	Minimum from property line (feet)	Minimum distance from nearest single story building (feet)	Minimum distance from nearest building two stories or greater in height (feet)
Rural En	vironment	•	ons live within 2 miles o	f the proposed
≤ 25	3 feet	generator.  Zero	109	109
223	4.5 feet	Zero	94	94
	6 feet	Zero	69	69
	10 feet	Zero	Zero	Zero
> 25 to	3 feet	Zero	148	352
50	6 feet	Zero	110	401
	10 feet	Zero	Zero	Zero
> 50 to	6 feet	Zero	132	395
100	10 feet	Zero	Zero	Zero
Urban En	vironment		live within 2 miles of th	
≤ 25	3 feet	Zero	Zero	Zero
	4.5 feet	Zero	Zero	Zero
	6 feet	Zero	Zero	Zero
	10 feet	Zero	Zero	Zero
> 25 to	3 feet	Zero	79	79
50	6 feet	Zero	Zero	Zero
	10 feet	Zero	Zero	Zero
> 50 to	6 feet	Zero	Zero	188
100	10 feet	Zero	Zero	Zero

General Order of Approval No. XXXX Diesel-fired emergency generators Page 3 of 8

#### Process to apply for coverage

Submit:

1. The appropriate application forms.

Contact the Ecology office which covers the location of your proposed emergency generator set installation for a copy.

**Table 3: Ecology Permit Issuing Offices** 

Air Quality Program	Air Quality Program
Central Regional Office	Eastern Regional Office
15 West Yakima Ave Suite 200	N. 4601 Monroe
Yakima, WA 98902-3452	Spokane, WA 99205-1295
Tel. No 509-575-2490	Tel. No 509-329-3400
Industrial Section	Nuclear Waste Program
PO Box 47600	Hanford Unit
Olympia, WA 98504-7600	3100 Port of Benton Blvd.
Tel. No.	Richland, WA 99354
	Tel. No. 509-372-7950
On the internet at:	
http://www.ecy.wa.gov/programs/air/airhome.html	

- 2. The application/coverage fee of \$500
- 3. Documentation of SEPA compliance

If SEPA for this project has been done by another agency, submit copy of Determination of Nonsignificance, Mitigated Determination of Nonsignificance, or Environmental Impact Statement issued for the project

If SEPA has not been done by another agency, submit a completed SEPA checklist and our SEPA processing fee of. A copy of the checklist is available from the above contacts or on the internet at <a href="http://www.ecy.wa.gov/biblio/forms-sepa\_forms.html">http://www.ecy.wa.gov/biblio/forms-sepa\_forms.html</a>.

#### **Granting of Coverage**

For those units that qualify for coverage, the applicant will receive a Coverage Order within 30 days after the complete application has been received.

For those units that do not qualify for coverage, the applicant will receive a letter from Ecology within 30 days after the application has been received. The letter will state why the unit does not qualify for coverage under this General Order of Approval.

# **Approval Conditions**

## 1. General and siting criteria

Parameter	Requirement or limitation
Fuel usage requirements	Low-sulfur content: Not greater than 500 parts sulfur per million by weight (ppmw).
Annual hours of use	Not more than 30 hours in any calendar year for required testing, and not more than 500 hours total operation in any calendar year.
Exhaust stack	Vertical exhaust.
	Minimize bends, obstructions, and building interference with exhaust dispersion.
	A minimum of ten feet above the roofline or compliant with the requirements in <b>Table 2</b> .
Minimum distance from stack to property line and to publicly-accessible buildings	No restriction if stack is at least ten feet above the roofline.
	If stack is less than ten feet above the roofline, distances must comply with the requirements in <b>Table 2</b> .
	If publicly-accessible buildings are constructed after submittal of this application that are within the distance limitation indicated in Table 2, permittee will immediately notify in writing the permit issuing office (Table 3).
	If the building being serviced by the emergency generator set is converted from private access to publicly-accessible, permittee will immediately notify in writing the permit issuing office (Table 3).

## 2. Diesel engine qualifications: 40 CFR Part 60 Subpart IIII (as proposed July, 2005)

<b>Engine Powe</b>	er	Tier	Engine	Carbon	Non-methane	Particulate
Brake horsepower (BHP)	Kilowatts		model year effective	monoxide grams per BHP per hr	hydro- carbons plus nitrogen oxides grams per BHP per	matter grams per BHP per hr
					hr	
Less than	Less than	Tier 2	2005 and	6.0	5.6	0.6
11	8		after			
25 to less	8 to less	Tier 2	2005 and	4.9	5.6	0.6
than 25	than 19		after			

25 to less than 50	19 to less than 37	Tier 2	2004 and after		4.1		5.6		(	0.45
50 to less than 100	37 to less than 75	Tier 2	2004 through 2007		3.7		5.6		(	0.3
		Tier 3	200 afte	08 and er	3.7		3.5		(	0.3
100 to less than 175	75 to less than 130	Tier 2	2003 through 2006		3.7		4.9		(	0.22
		Tier 3	200 afte	)7 and er	3.7		3.0		(	0.22
175 to less than 300	130 to less than 225	Tier 2	2003 through 2005		2.6		4.9		(	0.15
		Tier 3	200 afte	)6 and er	2.6		3.0		(	0.15
300 to 500	225 to 375	Tier 3	2006 and after		2.6		3.0		(	0.15
501 to 530	376 to 398	Tier 3	2006 a after			2.6	•	3.0	•	0.15
		Engine design compliant with 40 CFR 63 Subpart ZZZZ: Formaldehyde emissions less than or equal to 350 parts per milli (dry volume basis).								
Greater than 530	Greater than 398	-	Not permitted under this general order. Standard new source review required.							

# 3. Emission limitations monitoring, recordkeeping and reporting requirements

Pollutant or	<b>Limitation(s)</b>	Monitoring	Recordkeeping	Reporting
parameter				
Fuel usage	No limit	Diesel fuel purchase records	Vendor's certification for diesel fuel quality for all purchases.	None
			Keep for 3 years from date of purchase.	
			Provide records to Ecology within 10 business days of request.	

Pollutant or parameter	Limitation(s)	Monitoring	Recordkeeping	Reporting
Hours of operation	Not more than 30 hours per year for required testing.  Not more than 500 hours per year total operating time.	Non-resettable hour meter	Cumulative calendar year operating hours.  Keep most recent 3 years' records.  Provide records to Ecology within 10 business days of request.	None
Pollutant emissions	Compliant with the emission standards in 40 CFR Part 60 Subpart IIII.	None	Documentation from manufacturer that engine is certified to meet 40 CFR Part 60 Subpart IIII standards.  Provide documentation to Ecology within 10 business days of request.	None
Visible emissions	10% exclusive of visible condensed water vapor as measured by EPA Method 9, 40 CFR Part 60, Appendix A (July 1, 2000).	Once each day during periods of operation, observe stack for visible emissions (smoke coming from the stack).	In either a permanent-bound log book or in readily accessible computer memory, record dates and times of observation and whether smoke can be seen coming from the stack.  If smoke can be seen coming from the stack, record any corrective	If corrective action fails to eliminate visible smoke within 24-hours, report in writing to permit issuing office (Table 3).

General Order of Approval No. XXXX Diesel-fired emergency generators Page 7 of 8

Pollutant or parameter	Limitation(s)	Monitoring	Recordkeeping	Reporting
			actions taken.	
			Provide records to Ecology within 10	
			business days of request.	

#### Daily visual stack exhaust observation procedure:

Observe the emergency generator set stack exhaust during daylight hours while the generator is in operation. Observe the exhaust from the stack from a location with a clear view of the stack and where the sun is not directly in the observer's eyes. The observer shall be at least 15 feet but not more than 0.25 mile from the stack.

#### **Other Conditions of Approval**

- 4. The emergency generator set installed shall be the one described in the application and Order issued granting coverage under this General Order of Approval.
- 5. The emergency generator set shall be installed where and as described in the permit application.
- 6. The permittee shall submit to Ecology the date installation of the emergency generator set is started and completed<sup>1</sup>.
  - a. This Order shall become invalid if installation of the generator set is not begun within 18 months after receipt of final approval, if installation is discontinued for a period of 18 months or more, or if construction is not complete in a period of time deemed reasonable by Ecology.
  - b. Ecology may extend these deadlines upon a satisfactory showing that an extension is justified. The extension request must be received by the Ecology prior to expiration of the Order.
- 7. Operation and Maintenance.

a. The permittee is to follow all recommended operation and equipment maintenance provisions supplied by the manufacturer of the unit.

- b. If the visual inspection for opacity indicates that any smoke can be seen, the permittee is to take immediate steps to bring the generator back into compliance with the limitation.
- 8. Periodic emissions inventory information and other information may be requested by the Ecology. Information requested by Ecology shall be submitted within 30 days of receiving the request unless otherwise specified. Ecology will supply the necessary forms to use for periodic emission inventory.

<sup>&</sup>lt;sup>1</sup> Electronic mail submittals of the notifications to the approving office are encouraged to reduce paperwork.

General Order of Approval No. XXXX Diesel-fired emergency generators Page 8 of 8

- 9. Annual/periodic Registration or Air Operating Permit fees. The applicant will pay the required registration fees within 30 days of receipt of the invoice from Ecology.
- 10. Access to the source for the purpose of determining compliance with the terms of this General Order of Approval by Ecology staff shall be permitted during normal business hours. Failure to allow such access is grounds for an enforcement action under the Washington State Clean Air Act.
- 11. The applicant is required to comply with applicable rules and regulations pertaining to air quality, and conditions of operation imposed upon issuance of this order. Any violation of applicable state and/or federal air quality rules and regulations or of the terms of this approval shall be subject to the sanctions provided in Chapter 70.94 RCW. Authorization under this Order may be modified, suspended, or revoked in whole or part for cause including, but not limited to, the following:
  - a. Violation of any terms or conditions of this authorization;
  - b. Obtaining this authorization by misrepresentation or failure to disclose fully all relevant facts.
- 12. The provisions of this General Order of Approval are severable and, if any provision of this authorization, or application of any provisions of this authorization to any circumstance, is held invalid, the application of such provision to their circumstances, and the remainder of this authorization, shall not be affected thereby.

### **Legal Basis to Issue This General Order of Approval**

The Department of Ecology Air Quality Program is issuing this General Order of Approval as allowed under Washington Administrative Code (WAC) 173-400-560. Receipt of a Coverage Order for installation of a specific unit under this approval satisfies the requirements of WAC 173-400-110.

### **Approvals**

PREPARED BY:	APPROVED BY:
Date:	Date
Bernard Brady, PE	Stuart A. Clark, Program Manager
Air Quality Program	Air Quality Program
Department of Ecology	Department of Ecology